



ADDENDUM NO. 1

16 August 2017

To all Bidders on the Project titled:

Elm Street Cemetery Cast Iron Fence Restoration
Elm Street/Railroad Street
Braintree, MA 02184

Reference Contract Documents (drawings and specifications) dated 21 July 2017.

The attention of bidders submitting bids for the above subject project is called to the following addendum to the specifications and drawings. The items set forth herein, whether of omission, addition, substitution, or clarifications are all to be included in and form a part of the bid submitted.

THE NUMBER OF THIS ADDENDUM (1) MUST BE ENTERED IN THE APPROPRIATE SPACE "B" PROVIDED AFTER THE WORD "NUMBERS" OF THE CONTRACT FORM ENTITLED "FORM FOR GENERAL BID," AND IN SPACE "B" OF THE "FORM FOR SUB-BID."

Drawings:

See attached complete set of drawings dated 7/21/2017 UP #1. These drawings supersede all other drawings issued.

Questions:

1. Will the permit fee be waived by the town.

Answer:

There will be no permit or permit fee required.

2. What is the material for the sub rail.

Answer:

The sub rail is to be cast iron in both the base bid and in Alternate #1. Specification section 01030 – Alternates Part 1.2 Paragraph 1 to be revised to read "Alternate #1: Provide and install three coat zinc primer, epoxy mid coat, polyurethane top coat paint system in lei of galvanized coating. Install stainless steel bottom bar, ~~and sub-rail~~ in lei of Carbon Steel.

All other portions of the Contract Documents remain **unchanged**. Please be reminded to acknowledge this Addendum on the bid forms.

--- End of Addendum No. 1 ---